

P.O. Box 10246
Birmingham, Alabama 35202

Telephone: 205 849-1300
Telex: 82-1269



September 18, 1991

Mr. Wayne Studyvin, Engineer
Bureau of Environmental Health
Jefferson County Department of Health
P. O. Box 2648
Birmingham, Alabama 35202

Dear Mr. Studyvin,

We are pleased to formally notify you that all equipment required to provide compliance with 40 CFR 61 Subpart L was placed in operation on September 12, 1991. Performance testing observed by your personnel was performed on September 13, 1991. Observations were verified using an independent consultant, ATEC. Two small leaks were identified, corrected, and retested in compliance. Copies of the test records are attached.

Sincerely,

ABC COKE DIVISION

A handwritten signature in cursive script, appearing to read 'S. W. Morgan'.

S. W. Morgan
Environmental Engineer

cc: ADEM
EPA Region IV

SWM\kh